

City of Streetsboro

Administrative Offices
9184 St. Rt. 43
Streetsboro, Ohio 44241-5322
(330) 626-4942



Service Department
2094 St. Rt. 303
Streetsboro, Ohio 44241-1707
(330) 626-2856

Waterline Installation Rules

Depth- 4' minimum; 4'6" minimum under pavement

Gas Lines- minimum 10' distance

Property Lines- minimum 5' from side lot lines

Septic Systems- minimum 50' from trench

Sanitary- If at same depth as the water line (10') foot lateral separation is required. If at different depths an 18" vertical crossing separation is required.

Material

3/4" To 2" lines: 'K' Copper only

3" and Up: Ductile Iron Pipe Only

3/4" to 1": Flare to Flare only

1 1/2" - 2": Flare to Flare preferred but will accept compression.

Fill

Six inches of sand bedding are required on 1" lines or larger. For 3/4" service lines six inches of sand bedding preferred but if using onsite fill then it must be debris and rock free.

Water for Construction Use

There will be no construction water off of fire hydrants. The only Hydrant you may fill off of is located at the City of Streetsboro Service Department. At the time of filling a Bulk Water Log will be filled out. Persons caught on any other Hydrant faces legal charges.

Testing

You must call 24 hours in advance to schedule a ditch inspection.

All lines over 1" require Hydrostatic testing and bacterial tests that are done for a fee by the Streetsboro Water Dept. and require prior scheduling, also.

If you have any questions, please contact the Water Dept. @ 330-626-2856